

**MUNICIPAL CORPORATION OF DELHI
KASTURBA HOSPITAL
DARYA GANJ, NEW DELHI-110002**

KH/Purchase/2022-23/01

Dated: 13/07/2022

Subject: Invitation for Quotations.

Quotations are invited for the Purchase of Air Ducting and Installations in Kitchen Department, Kasturba Hospital.

S.No	Description of work/Item As Below	Total no. of Items. As below	Quotation to be submitted in the Office of Addl. M.S./KH Latest by 12 Noon on 25.07.2022 and will be opened on same day at 2:00 PM
1	Purchase and Installation of Air Ducting System	01	

Specifications:-

1. Exhaust Hood of size 98"X 42" X 18".
2. External and internal parts should be manufactured in SS 202.
3. It should have 20Gauge Welded Body Construction.
4. Should have Removable 22 Gauge S.S "V" section.
5. It should be measuring 510*510*50 mm thick.
6. Full length w/bottom of filters should be set in continuous channel.
7. Grease gutter must be on rear and side in each piece.
8. Should have appropriate numbers of Flushed glass lights.
9. Should be verified by site/coordinate HVAC consultants..
10. Size must be according to requirement of CFM
11. It should have Feature of Commercial Heavy Duty
12. Brand must be ISI marked.
13. Mounting Type should be Window Mount
14. Dimensions must be : 68 x 68 Centimeters
15. Material should be Copper
16. It should have Input Power 550 W Single Phase.
17. Including Civil and Electrical Work needed for installation.
18. Including Maintenance and Cleaning of filter.
19. 2-3 year warranty.
20. Fabricating, Providing, Installing, Testing & Commissioning of Air ducting system should be done.
21. It should include AMC of Air ducting systems for Five Years.
22. Rates of spare parts under AMC to submitted at the time of purchase/work order.

- General Terms and Conditions

The firms should submit the following:-

- (a) Copy of PAN Number
- (b) Copy of GST Registration No.
- (c) Should provide at a rate which is lesser than or equal to at which supplied to govt. hospital including MCD.
- (d) Should have the minimum 5 years experience of eligibility criteria.
- (e) Should not be blacklisted.


Addl.MS
Kasturba Hospital

Distribution :

1. Kasturba Hospital Website (To Assistant Programmer/Concerned to upload/email the same)
2. Notice Board Kasturba Hospital.
3. Notice Board of Hindu Rao Hospital, RBIPMT, GLMHSDNH, ID Hospital, GB Pant and LNJP Hospital.
4. Nodal Officer (Kitchen)/KH.
5. Office Copy.